Fe0-based environmental remediation

Subjects: Engineering, Biomedical Contributor: Chicgoua Noubactep, Viet Cao

The technology of using metallic iron (Fe0) for in situ generation of iron oxides for water treatment is a very old one. The Fe0 remediation technology has been re-discovered in the framework of groundwater remediation using permeable reactive barriers (PRBs). Despite its simplicity, the improvement of Fe0 PRBs is fraught with difficulties regarding their operating modes. The literature dealing with Fe0 remediation contains ambiguities regarding its invention and its development. The present paper examines the sequence of contributions prior to the advent of Fe0 PRBs in order to clarify the seemingly complex picture.

Keywords: Decentralized solutions ; Groundwater remediation ; Historical perspectives ; Lab-scaled investigations ; Porosity loss ; Reactivity loss ; Research and development ; Safe drinking water ; Wastewater treatment ; Zerovalent iron

1. Introduction

The world is facing a problem of continuously decreasing availability of fresh water $^{[1][2][3][4]}$. This is because natural water resources are progressively polluted with anthropogenic chemicals, including chlorinated hydrocarbons $^{[5][6]}$. Previous efforts to remediate polluted groundwater have culminated in the development of permeable reactive barriers (PRBs) $^{[2][8]}$. PRBs are subsurface filters filled with appropriate materials to treat through-flowing polluted waters. PRBs containing granular metallic iron (Fe⁰) have been demonstrated as an economically-feasible, environmentally friendly, and technologically simple approach for groundwater remediation $^{[9][10][2][3][4][11]}$. In addition, PRBs are applicable to a broad range of chemical species, and are less vulnerable to environmental conditions $^{[11][12]}$.

The development of the Fe⁰ PRB technology is currently believed to be fraught with two major difficulties: Reactivity loss and permeability loss ^[11]. Both aspects are inherent to aqueous iron corrosion and occur everywhere, unless appropriate countermeasures are developed ^{[13][14]}. Reactivity loss is perceived as the decrease of electron transfer from Fe⁰ to contaminants over time caused by the formation of an oxide scale on the Fe⁰ surface (or in its vicinity). On the one hand, a quantitative electron transfer is impaired by the non-conductive nature of the named oxide scale. On the other hand, permeability loss is perceived as filling the pore space of Fe⁰-based filters mainly by foreign precipitates (e.g., CaCO₃) or mixed precipitates (e.g., FeCO₃). However, at pH > 4.5, aqueous iron corrosion is a volumetric expansive process ^{[15][16]} ^[17], meaning that the very first cause of permeability loss is pore filling with iron oxides and hydroxides ^{[18][19]}. Luo et al. ^[18] have recently demonstrated porosity loss in a Fe⁰ filter fed by deionised water (no contaminant, no foreign minerals).

The presentation until now demonstrates that the development of the Fe⁰ PRB technology has been based on considering Fe⁰ as a reducing agent. This view implies that iron corrosion by water (the solvent) is a side reaction. The net result is an underestimation of the importance of pore filling by solid iron corrosion products (FeCPs). Considering Fe⁰ as a reducing agent has culminated in the introduction of the electron efficiency concept (EE concept) ^{[20][21][22]}. The EE concept aims at optimizing the Fe⁰ amounts in PRBs in order to avoid material wastage. The EE concept characterizes the redistribution of electrons from Fe⁰ to dissolved O₂, target contaminants, and co-contaminants (e.g., NO₃⁻). The EE concept frontally contradicts the fact that contaminant reductive transformation and Fe⁰ oxidative dissolution are not simultaneous processes (electrochemical reaction) ^{[23][24][25]}. There is thus a need to clarify the root role of Fe⁰ in PRBs and related filtration systems.

2. Methodology

The literature reviewed herein corresponds to the one published in the peer-reviewed literature prior to the advent of Fe⁰ PRBs ^{[26][27][28][29]}. No systematic review is performed, rather, studies relevant in answering the research questions were selected. Metal recovery with cementation using Fe⁰ ^{[30][31]} and heavy metal removal from industrial wastewaters ^{[32][33]} are not considered. The use of Fe⁰ in organic synthesis ^[34] is just considered to specify the reaction conditions which do not correspond to environmental conditions. Typically, organic synthesis by metals (including Fe⁰) occurs in acidic aqueous solutions (pH < 7.0) and at elevated temperatures (e.g., > 30 °C) ^{[34][35][36]}.

3. Fe⁰ in Organic Synthesis: The Béchamp Reduction

Reduction of organics with metals has been known for many decades, but there is no commonly accepted theory of the process. A general agreement exists that hydrogen species are involved in these reductive transformations. In these reactions, double-bonds are broken; halogen atoms are replaced by hydrogen or removed entirely with formation of double bonds; while nitrile, thiocyanide, and other nitrogen and sulfur-containing groups are destroyed [36]. The oldest known reaction involving Fe⁰, and used on an industrial scale is probably the synthesis of aniline after the Béchamp reduction ^{[37][38]}.

The Béchamp reduction (Béchamp process) implies the chemical reduction of aromatic nitro compounds to amines in the presence of Fe⁰ and in dilute acid (iron and acid). In the original version of the Béchamp process, nitrobenzene was used to produce aniline in the presence of iron filings or shavings in a dilute hydrochloric acid. It was postulated that reduction was mediated by Fe⁰ (electrons from the metal body), and that a slightly acidic pH value was needed (optimum 5.5 £lpH £l0.6) ^[39]. However, over the years, it was discovered that the reaction was more or less quantitative in organic acids (e.g., HCOOH) and even in NaCl. This implies that Fe²⁺ ions (stabilized by Cl⁻) are able to induce the reduction of nitrobenzene. For details, interested readers are referred to annual reviews on "Amination by reduction" published between 1951 and 1961 by Jesse Werner in Industrial and Engineering Chemistry (American Chemical Society) ^[38]. For the current presentation, it suffices to recall that: (i) The reactants are pre-heated and then passed through a suitable heated reactor, (ii) ferrous salts could also initiate the chemical reduction of aromatic compounds, and (iii) aniline is removed both from the reaction vapors and the bulk solution (not at the Fe⁰ surface). Moreover, lower aniline recovery was explained by its occlusion in the matrix of solid iron corrosion products (FeCPs) as the final pH values were constantly higher than 5.0 ^{[39][40]}.

Summarizing, the century-old Béchamp reduction reveals that organics can be quantitatively reduced by Fe^{2+} ions in the bulk solution, but at elevated temperatures (e.g., > 50 °C). In other words, Fe^{0} is "just" a generator of Fe^{2+} for the reductive transformation of nitrobenzene, and the reaction is possibly catalyzed by Fe^{0} and solid FeCPs (e.g., $Fe(OH)_{2}$, $Fe(OH)_{3}$), and the reaction products are quantitatively available in the bulk solution. In the Fe^{0} remediation technology, pollutants (e.g., nitrobenzene) and reaction products (e.g., aniline) must be removed from the aqueous phase. This is particularly true for safe drinking water provision. However, as a rule, in the concentration range of natural waters, chemical reduction is not a contaminant removal mechanism. In fact, the residual concentrations of the parent chemical and reaction products as per the equilibrium constant, are larger than the maximum permissible contamination level in most of the cases ^[41].

4. Fe⁰ for Safe Drinking Water Provision

In his historical textbook on water treatment, Davis ^[42] highlighted the following materials as potentially suitable for safe drinking water provision in filtration systems: Animal charcoal, bricks, carbonide of iron, coke, compressed sponge, porous tiles, sand, spongy iron, unglazed earthenware, and wood charcoal. From this list, two materials are Fe⁰-based: Carbonide of iron and spongy iron. Spongy iron was explicitly described for its capacity for "removal and destruction of organic matter". Filtration systems are often operated under ambient conditions (about 20 °C) and without pH adjustment. In other words, as early as the end of the 19th century, Fe⁰ was used for the abiotic or chemical destruction of organic matter and nitrates under environmental conditions ^[43]. Remember that pioneers of the Fe⁰ PRBs have traced this process back to the 1970s. Admittedly, organics of concern were not halogenated carbons, but the ancient literature on water treatment using the Fe⁰ system remains largely unexploited ^[44]. The three known ancient Fe⁰-based systems for safe drinking water provision will be briefly presented in this section.

4.1. The Bischof Process

In 1871, Prof. Gustav Bischof (Glasgow) patented a system for water treatment at the household level using spongy iron as a reactive material $^{[45][46]}$. Porous spongy iron or sponge iron corresponds to direct reduction of iron and was the best innovation in efforts to use Fe⁰-materials in a decentralized water treatment as summarized by Mwakabona et al. . The Bischof process was then tested and used for the water supply of the city of Antwerp (Belgium) (10,000 m³ d⁻¹) between 1881 and 1883 $^{[47]}$. The Bischof process (Figure 1) could efficiently supply the city with safe drinking water for 18 months without any perturbation or need for maintenance. However, after 18 months, the filters experienced clogging and could no longer produce enough water to cover the needs of the 200,000 inhabitants. Hence, it became necessary to adopt a more rapid system: The revolving purifier or Anderson process $^{[47][48]}$.

A careful examination of the origin of filter clogging clearly traced it to the Fe⁰/gravel layer (Figure 1). In this layer, gravel and Fe⁰ particles were cemented to a compact mass which locally reduced the interconnectivity of available pore spaces and the hydraulic conductivity (permeability) of the whole filter. The rationale for the use of the volumetric Fe⁰/gravel ratio of 1/3 (25% Fe⁰) was not given in Davis and could not be found in the original works of Bischof . The volumetric expansive nature of iron corrosion was also not yet discovered by then. However, the implementation of the Bischop process in Antwerp had clearly demonstrated that Fe⁰-based filters are prone to clogging caused by iron corrosion. Since the Fe⁰ proportion matters, it can be postulated that higher Fe⁰ ratios (e.g., 50, 75, or 100%) would have yielded less sustainable Fe⁰ filter systems (less than 18 months of service life).



Figure 1. Schematic diagram of the Bischof's spongy iron filter as described by Davis [42]. Arrows show the direction of water flow.

4.2. The Anderson Process

In 1885, Anderson patented the "revolving purifier" and used it in Antwerp to replace the spongy iron filters . The revolving purifier entails vigorously churning up the polluted water for up to 5 min with Fe^0 filings or shavings in a cylinder. During this time, iron hydroxides precipitate and occlude contaminants, including organic matters. The flocs are then removed in a subsequent filtration on gravel and sand. In other words, the Anderson process roughly corresponds to coagulation/flocculation, wherein flocs are not generated by iron salts but are in situ produced from Fe^0 . It is obvious that the Bischof process relies on the same principles, with the subtle but important difference that iron precipitation occurs in the vicinity of Fe^0 particles and not in the bulk solution. The subsequent Emmons process intuitively used this evidence. The Anderson process could produce up to 20,000 m³ d⁻¹ in Antwerp.

4.3. The Emmons Process

Around 1950, the US Atomic Energy Commission initiated research to thoroughly investigate the decontamination of water polluted with radionuclides at a decentralized level. The tested methods included adsorption, coagulation, distillation, and ion exchange. While investigating adsorptive methods, Lauderdale and Emmons ^[49] found that steel wool (Fe⁰ SW) was capable of quantitatively removing radioactivity from the aqueous phase. This observation led to the investigation of powdered metals (e.g., Al⁰, Cu⁰, Fe⁰, Zn⁰) as an alternative to Fe⁰ SW for the removal of radioactivity from water ^[50].

The patented Emmons process [51] was a promising water treatment technology for decentralized safe drinking water provision. It entails using a mixed bed ion exchange in conjunction with another bed filled with Fe⁰ SW, clay, and activated carbon. However, the systems were outcompeted by pure ion exchange systems, partly because of its selectivity towards negatively charged radionuclides [52][53]. The merit of the Emmons process was to reiterate the crucial importance of permeability loss in Fe⁰-based filters, while revealing the importance of multi-barrier systems to account for the specificities of individual contaminants.

The presentation of the ancient Fe^{0} technology for safe drinking water demonstrates that already in the 1950s, Fe^{0} and other elemental metals (e.g., Al^{0} , Cu^{0} , Fe^{0} , Zn^{0}) were demonstrated as powerful reactive materials for the removal of nitrate, organic substances, pathogens, and radionuclides from polluted waters. The corresponding filtration systems, working under ambient conditions (e.g., O_{2} level, temperature), were plagued by permeability loss certainly due to solid FeCPs. However, the volumetric expansive nature of iron corrosion as demonstrated by Pilling and Bedworth was not considered in solving the clogging problem. Instead, Lauderdale and Emmons used a grade 0 (d = 50 mm) Fe⁰ SW and suggested the use of coarser Fe⁰ SW or granular Fe⁰ (d > 50 mm) to avoid (or delay) clogging. Oldright et al. partly justified permeability loss of Fe⁰ filters by larger Pb²⁺ ions replacing Fe²⁺ in filters. This plausible argument has equally not considered the volumetric expansion of Fe.

5. Fe⁰ for Agricultural Wastewater

The need for an affordable solution for wastewater treatment, particularly water containing high levels of phosphate is a classic example of how technology can be rediscovered in different contexts. For example, Section 4 has already pointed out how the Emmons process was discovered independently from the Bischof process. In 1992, while seeking for applicable and cost-effective solutions for phosphate removal from wastewaters, George Frigon suggested Fe^0 SW as a good material to in situ generate "oxides" for phosphate removal [^{54]}. In this communication, this tool will be operationally termed the Frigon process. One key advantage of the Frigon process is that, Fe^0 SW is readily available and is acceptable "from an engineering viewpoint". In 2007, Andrew J. Erickson independently presented the Frigon process is particularly interesting because it was introduced more than a decade after the advent of the Fe⁰ PRB technology, but was introduced as a stand-alone technology. Only in the further development of the Erickson process was the knowledge from the Fe⁰ PRB considered [^{56][57]}. For example, it was suggested that Fe⁰ SW was replaced by the granular Fe⁰. Another interesting feature of the Erickson process is that, it used only less than 5% by weight of Fe⁰ SW and was efficient for years without any clogging problems[^{56]}.

Another field of application where Fe^0 presented promising results is that of Se removal from agricultural drainage water. Filtration on Fe^0 beds was investigated as a feasible, cost-effective, and practical alternative to biological precipitation, flow-through wetlands, ion-exchange, microalgal-bacterial treatment, reverse osmosis, solar ponds, and volatilization ^[58]. In 1985, the Harza Engineering Company tested a pilot-scale process using iron filings in flow-through beds to remove Se from agricultural drainage water (Harza process) ^[59]. Se removal was quantitative, but the testing was discontinued because the columns quickly cemented with precipitates (FeCPs). It was first postulated that Fe^0 reduces Se^{VI} to Se^{IV} and Se^0 . Further studies conclusively demonstrated that Se was not reduced by Fe^0 (no electrochemical mechanism), but rather, by Fe^{II} species generated in situ ^[60]. Anderson ^[60] also demonstrated that Se was removed by adsorption onto and co-precipitation with FeCPs, despite the observed chemical reduction. The tested filter beds contained 100% Fe^0 and were very efficient at removing Se, but were not sustainable due to clogging. Testing the Harza process has demonstrated that Fe^0 filtration can decrease Se concentrations to very low values and suggested that the Harza process "might be useful as a polishing step following microbial treatment" ^[58]. However, the Erickson process suggests that decreasing the Fe^0 proportion in the beds (e.g., 25% v/v) would make the Harza process a stand-alone sustainable technology for selenium removal.

6. Fe⁰ for Domestic and Industrial Wastewaters

Previous sections have demonstrated the ability of Fe^0 filters to treat water polluted with organic matter, phosphate, and nitrate, which are three main components of human wastes. Thus, Fe^0 filters are also a good candidate for the decentralized treatment of domestic wastewaters. Conventional methods for decentralized domestic wastewater treatment include lagoons, sand filters, and wetlands. However, these technologies presented numerous drawbacks, such as evaporation of huge quantities of valuable water, generation of significant odor, and high demand for land. Additionally, their treatment performance depends on seasonal variations and require frequent maintenance operations.

In 1993, Wakatsuki et al. [61] presented in the English peer-reviewed literature a system first published between 1989 and 1991 in Japanese (*Jpn. J. Soil Sci. Plant Nutri.*). Then, the new Fe⁰-based wastewater treatment technology is termed as a multi-soil-layering (MSL) system. In a MSL system, Fe⁰ in soil is oxidized to ferrous ions which in situ coat the available surface (e.g., in zeolite layers), and are oxidized further to ferric iron which can fix phosphate ions. Fe⁰ oxidation consumes oxygen and contributes to the development of anaerobic conditions. The MSL system has been successfully tested for domestic wastewater treatment in several countries over the past 30 years [62][63][64]. Compared to the other alternatives discussed earlier, the MSL technology is very cost effective and has an effective service life estimated to be more than 20 years. The MSL system has several advantages, including (i) occupies a small area, (ii) has a high hydraulic capacity, (iii) simple maintenance and no frequent clogging, and (iv) requires no energy ^[62]. Therefore, the MSL system has the potential to become a sustainable domestic wastewater treatment option in low-income communities in the developing countries. MSL are very flexible systems which can be selectively designed with available materials. Their huge potential in achieving universal sanitation cannot be overemphasized.

The very last important aspect of the ancient Fe^0 literature is the concept for wastewater treatment presented in 1991 by Michael Boris Khudenko. Khudenko suggested the use of cementation using Fe^0 as a tool to reductively degrade organics in wastewaters. Clearly, a copper salt (e.g., $CuSO_4$) was used to oxidize Fe^0 (Equation (1)) to produce Fe^{II} species, which in turn reduce organics in a parallel (not simultaneous) reaction (Equation (2)). Contaminant degradation is

optimal at lower pH values (H⁺ consumption), and its extent depends on the Cu²⁺ concentration, among other parameters. The Fe⁰ PRB literature has mostly considered that contaminants are reduced by Fe⁰ (Equation (3)), while Fe⁰ corrosion by water (Equation (4)) has been regarded as a side reaction.

 $Fe^{0} + Cu^{2+} = Cu^{0} + Fe^{2+}$ $2 Fe^{2+} + RCI + H^{+} = 2 Fe^{3+} + RH + CI^{-}$ $Fe^{0} + RCI + H^{+} = Fe^{2+} + RH + CI^{-}$ $Fe^{0} + 2 H^{+} = Fe^{2+} + H_{2}$

The most trivial argument against Equation (3) is the presence of a non-conductive oxide scale shielding the Fe⁰ surface, hence electron transfer from Fe⁰ to the contaminant is impossible ^[65]. On the other hand, chemical reduction according to Equation (3) was documented in the Béchamp process (Section 3). In other words, before the mechanistic discussion initiated by Matheson and Tratnyek in the framework of research for Fe⁰ PRBs, the scientific literature had already presented evidence that at a pH value of natural waters, contaminants are quantitatively removed in well-designed Fe⁰/H₂O systems. As demonstrated herein, Fe⁰ is corroded by water (Equation (4)), while contaminants are reduced in parallel reactions (Equation (2)).

References

- Howe, K.J.; Hand, D.W.; Crittenden, J.C.; Trussell, R.R. Tchobanoglous, In Principles of Water Treatment; John Wiley & Sons, Inc.: Hoboken, NJ, USA, 2012; p. 674.
- Henderson, A.D.; Demond, A.H. Long-term performance of zero-valent iron permeable reactive barriers: A critical revie w. Environ. Eng. Sci. 2007, 24, 401–423.
- 3. Gheju, M. Hexavalent chromium reduction with zero-valent iron (ZVI) in aquatic systems. Water Air Soil Pollut. 2011, 22 2, 103–148.
- 4. Ghauch, A. Iron-based metallic systems: An excellent choice for sustainable water treatment. Freiberg Online Geosci. 2 015, 32, 1–80.
- Detay, M.; Alessandrello, E.; Come, P.; Groom, I. Groundwater contamination and pollution in micronesia. J. Hydrol 198 9, 112, 149–170.
- Mackay, M.D.; Cherry, J.A. Groundwater contamination: Pump-and-treat remediation. Environ. Sci. Technol 1989, 23, 6 30–636.
- 7. McMurty, D.C.; Elton, R.O. New approach to in-situ treatment of contaminated groundwaters. Environ. Progr 1985, 4, 1 68–170.
- 8. Starr, R.C.; Cherry, J.A. In situ remediation of contaminated Ground water: The funnel-and-Gate System. Ground Wate r 1994, 32, 465–476.
- 9. O'Hannesin, S.F.; Gillham, R.W. Long-term performance of an in situ "iron wall" for remediation of VOCs. Ground Water 1998, 36, 164–170.
- Lee, G.; Rho, S.; Jahng, D. Design considerations for groundwater remediation using reduced metals. Korean J. Chem. Eng. 2004, 21, 621–628.
- 11. Guan, X.; Sun, Y.; Qin, H.; Li, J.; Lo, I.M.; He, D.; Dong, H. The limitations of applying zero-valent iron technology in co ntaminants sequestration and the corresponding countermeasures: The development in zero-valent iron technology in t he last two decades (1994–2014). Water Res. 2015, 75, 224–248.
- 12. Richardson, J.P.; Nicklow, J.W. In situ permeable reactive barriers for groundwater contamination. Soil Sediment Conta m. 2002, 11, 241–268.
- Bartzas, G.; Komnitsas, K. Solid phase studies and geochemical modelling of low-cost permeable reactive barriers. J. Hazard. Mater. 2010, 183, 301–308.

- Li, L.; Benson, C.H. Evaluation of five strategies to limit the impact of fouling in permeable reactive barriers. J. Hazard. Mater. 2010, 181, 170–180.
- 15. Pilling, N.B.; Bedworth, R.E. The oxidation of metals at high temperatures. J. Inst. Metals 1923, 29, 529–591.
- Caré, S.; Nguyen, Q.T.; L'Hostis, V.; Berthaud, Y. Mechanical properties of the rust layer induced by impressed current method in reinforced mortar. Cement Concrete Res. 2008, 38, 1079–1091.
- 17. Caré, S.; Crane, R.; Calabrò, P.S.; Ghauch, A.; Temgoua, E.; Noubactep, C. Modeling the permeability loss of metallic i ron water filtration systems. CLEAN—Soil Air Water 2013, 41, 275–282.
- Luo, P.; Bailey, E.H.; Mooney, S.J. Quantification of changes in zero valent iron morphology using X-ray computed tom ography. J. Environ. Sci. 2013, 25, 2344–2351.
- 19. Domga, R.; Togue-Kamga, F.; Noubactep, C.; Tchatchueng, J.B. Discussing porosity loss of Fe0 packed water filters at ground level. Chem. Eng. J. 2015, 263, 127–134.
- 20. Liu, H.; Wang, Q.; Wang, C.; Li, X.-Z. Electron efficiency of zero-valent iron for groundwater remediation and wastewat er treatment. Chem. Eng. J. 2013, 215–216, 90–95.
- He, F.; Gong, L.; Fan, D.; Tratnyek, P.G.; Lowry, G.V. Quantifying the efficiency and selectivity of organohalide dechlori nation by zerovalent iron. Environ. Sci. Process. Impacts 2020, 22, 528.
- 22. Gillham, R.W. Development of the granular iron permeable reactive barrier technology (good science or good fortune). I n Advances in Environmental Geotechnics, Proceedings of the International Symposium on Geoenvironmental Enginee ring in Hangzhou, China, 8–10 September, 2007; Chen, Y., Tang, X., Zhan, L. Eds.; Springer: Berlin, Germany; London, UK, 2008; pp. 5–15.
- 23. Noubactep, C. Flaws in the design of Fe(0)-based filtration systems? Chemosphere 2014, 117, 104–107.
- Noubactep, C. Research on metallic iron for environmental remediation: Stopping growing sloppy science. Chemosphe re 2016, 153, 528–530.
- 25. Xiao, M.; Hu, R.; Cui, X.; Gwenzi, W.; Noubactep, C. Understanding the operating mode of Fe0/Fe-sulfide/H2O system s for water treatment. Processes 2020, 8, 409.
- Gillham, R.W.; O'Hannesin, S.F. Enhanced degradation of halogenated aliphatics by zero-valent iron. Ground Water 19 94, 32, 958–967.
- 27. Lipczynska-Kochany, E.; Harms, S.; Milburn, R.; Sprah, G.; Nadarajah, N. Degradation of carbon tetrachloride in the pr esence of iron and sulphur containing compounds. Chemosphere 1994, 29, 1477–1489.
- Matheson, L.J.; Tratnyek, P.G. Reductive dehalogenation of chlorinated methanes by iron metal. Environ. Sci. Technol. 1994, 28, 2045–2053.
- 29. Schreier, C.G.; Reinhard, M. Transformation of chlorinated organic compounds by iron and manganese powders in buff ered water and in landfill leachate. Chemosphere 1994, 29, 1743–1753.
- 30. Gould, J.P.; Escovar, I.B.; Khudenko, B.M. Examination of the zinc cementation on cadmium in aqueous solutions. Wat er Sci. Technol. 1987, 19, 333–344.
- Noubactep, C. Elemental metals for environmental remediation: Learning from cementation process. J. Hazard. Mater. 2010, 181, 1170–1174.
- 32. Oldright, G.L.; Keyes, H.E.; Miller, V.; Sloan, W.A. Precipitation of lead and copper from solution on sponge iron. BuMin es B 1928, 281, 1–131.
- 33. Gould, J.P. The kinetics of hexavalent chromium reduction by metallic iron. Water Res. 1982, 16, 871–877.
- March, J. Advanced Organic Chemistry: Reaction Mechanism and Structure; McGraw-Hill Book Co: New York, NY, Unit ed States, 1968.
- 35. Werner, J. Amination by reduction. Unit Processes Review. Ind. Eng. Chem. 1961, 53, 77-78.
- Khudenko, B.M. Feasibility evaluation of a novel method for destruction of organics. Water Sci. Technol. 1991, 23, 187 3–1881.
- 37. Béchamp, A. De l'action des protosels de fer sur la nitronaphtaline et la nitrobenzine: Nouvelle méthode de formation d es bases organiques artificielles de Zinin. Ann. Chim. Phys. 1854, 42, 186–196.
- 38. Werner, J. Amination by reduction. Ind. Eng. Chem. 1951, 43, 1917–1919.
- Popat, V.; Padhiyar, N. Kinetic study of Bechamp process for p-nitrotoluene reduction to p-toluidine. Int. J. Chem. Eng. Applications 2013, 4, 401–405.
- 40. Noubactep, C. Relevant reducing agents in remediation Fe0/H2O systems. Clean—Soil Air Water 2013, 41, 493–502.

- 41. Kochenov, S.V.; Korolev, K.G.; Dubinchuk, V.T.; Medvedev, Y.L. Experimental data on the conditions of precipitation of uranium from aqueous solutions. Geokhimiya 1977, 11, 1711–1716.
- 42. Davis, F. An Elementary Handbook on Potable Water; Silver, Burdett & Co: New York, NY, USA; Boston, MA, USA; Chi cago, IL, USA, 1891; p. 118.
- 43. Hatton, F. On the oxidation of organic matter in water by filtration through various media; and on the reduction of nitrate s by sewage, spongy iron, and other agents. J. Chem. Soc. Trans. 1881, 39, 258–276.
- 44. Mwakabona, H.T.; Ndé-Tchoupé, A.I.; Njau, K.N.; Noubactep, C.; Wydra, K.D. Metallic iron for safe drinking water provi sion: Considering a lost knowledge. Water Res. 2017, 117, 127–142.
- 45. Bischof, G. The Purification of Water: Embracing the Action of Spongy Iron on Impure Water; Bell and Bain: Glasgow, U K, 1873; pp. 1–19.
- 46. Bischof, G. On putrescent organic matter in potable water. Proc. R. Soc. Lond. 1877, 26, 258–261.
- 47. Devonshire, E. The purification of water by means of metallic iron. J. Frankl. Inst. 1890, 129, 449-461.
- 48. Anderson, W. On the purification of water by agitation with iron and by sand filtration. J. Soc. Arts 1886, 35, 29–38.
- 49. Lauderdale, R.A.; Emmons, A.H. A method for decontaminating small volumes of radioactive water. J. Am. Water Work. Assoc. 1951, 43, 327–331.
- 50. Lacy, W.J. Removal of radioactive material from water by slurrying with powdered metal. J. Am. Water Work. Assoc. 19 52, 44, 824–828.
- 51. Emmons, A.H.; Lauderdale, J.R.A. Process for Water Decontamination. US Patent 2,752,309, 26 June 1956.
- 52. Swope, H.G. Mixed bed ion exchange for the removal of radioactivity. J. Am. Water Work. Assoc. 1957, 49, 1085–1102.
- Levin, H.; Diamond, W.J.; Brown, B.J. Influence of Ionic Strength on ion Exchange. Ind. Eng. Chem. 1959, 51, 313–31
 8.
- 54. James, B.R.; Rabenhorst, M.C.; Frigon, G.A. Phosphorus sorption by peat and sand amended with iron oxides or steel wool. Water Environ. Res. 1992, 64, 699–705.
- 55. Erickson, A.J.; Gulliver, J.S.; Weiss, P.T. Enhanced sand filtration for storm water phosphorus removal. J. Environ. Eng. 2007, 133, 485–497.
- 56. Erickson, A.J.; Gulliver, J.S.; Weiss, P.T. Capturing phosphates with iron enhanced sand filtration. Water Res. 2012, 46, 3032–3042.
- 57. Erickson, A.J.; Gulliver, J.S.; Weiss, P.T. Phosphate removal from agricultural tile drainage with iron enhanced sand. W ater 2017, 9, 672.
- 58. Frankenberger, W.T.; Amrhein, C.; Fan, T.W.; Flaschi, D.; Glater, J.; Kartinen, E.; Kovac, K.; Lee, E.; Ohlendorf, H.M.; O wens, L. Advanced treatment technologies in the remediation of seleniferous drainage waters and sediments. Irrig. Drai n. Syst. 2004, 18, 19–41.
- 59. Harza Engineering Co. Selenium Removal Study. Report to Panoche Drainage District; Harza Engineering Co.: Firebau gh, CA, USA, 1986.
- 60. Anderson, M.A. Fundamental aspects of selenium removal by Harza process. In Rep San Joaquin Valley Drainage Pro gram; US Department Interior: Sacramento, CA, USA, 1989.
- 61. Wakatsuki, T.; Esumi, H.; Omura, S. High performance and N, P removable on-site domestic wastewater treatment syst em by multi-soil-layering method. Water Sci. Technol. 1993, 27, 31–40.
- 62. Latrach, L.; Ouazzani, N.; Hejjaj, A.; Mahi, M.; Masunaga, T.; Mandi, L. Two-stage vertical flow multi-soil-layering (MSL) technology for efficient removal of coliforms and human pathogens from domestic wastewater in rural areas under arid climate. Int. J. Hyg. Environ. Health 2018, 22, 64–80.
- 63. Masunaga, T.; Sato, K.; Zennami, T.; Fujii, S.; Wakatsuki, T. Direct treatment of polluted river water by the multi-soil-lay ering method. J. Water Environ. Technol. 2003, 1, 97–104.
- 64. Chen, X.; Luo, A.C.; Sato, K.; Wakatsuki, T.; Masunaga, T. An introduction of a multi-soil-layering system: A novel green technology for wastewater treatment in rural areas. Water Environ. J. 2009, 23, 255–262.
- 65. Hu, R.; Gwenzi, W.; Sipowo-Tala, V.R.; Noubactep, C. Water treatment using metallic iron: A tutorial review. Processes 2019, 7, 622.