

# Fault Detection in DHC Systems

Subjects: **Energy & Fuels**

Contributor: Ismael Lozano-Gabarre

Peak shaving, demand response, fast fault detection, emissions and costs reduction are some of the main objectives to meet in advanced district heating and cooling (DHC) systems. In order to enhance the operation of infrastructures, challenges such as supply temperature reduction and load uncertainty with the development of algorithms and technologies are growing. Therefore, traditional control strategies and diagnosis approaches cannot achieve these goals. Accordingly, to address these shortcomings, researchers have developed plenty of innovative methods based on their applications and features. The main purpose of this article is to review recent publications that include both hard and soft computing implementations such as model predictive control and machine learning algorithms with applications also on both fourth and fifth generation district heating and cooling networks.

model predictive control

mixed-integer linear programming

load forecast

predictive maintenance

Fault detection

District Heating

District Cooling

## 1. Introduction

The world's level of urbanization is expected to increase from about 55% in 2018 to 68% in 2050, and 90% of this increment is expected to take place in Asia and Africa, which were home to about 90% of the world's rural population in 2018<sup>[1]</sup>. In Europe, 74% of the population lives already in urban areas today, and this percentage is expected to grow up to 84% by 2050<sup>[1]</sup>. Furthermore, in urban areas where the heating and cooling demand exhibits the highest density and the largest load simultaneity, a huge amount of low-grade excess heat is wasted. Moreover, for historical reasons, cities and towns have been born along rivers, lakes, and seashores that are all ambient heat sources in which utilization is highly replicable, because it is accessible right where it is needed. Even, in some cases, such as in London<sup>[2]</sup>, the total heat wasted from secondary sources has been estimated larger than the city's total heat demand.

Six out of ten of the top European heatwaves between 1950 and 2014 have appeared in the latest 20 years<sup>[3]</sup>. Extreme weather events, such as wind storms and flooding, have increased in number and intensity worldwide<sup>[4]</sup>. Some scientists claim that climate change's evolution and consequences have several similarities with the current pandemic crisis of COVID-19, but in slow motion<sup>[5][6]</sup>. Nevertheless, in the latest years, several public entities recognized the climate crisis and are going to implement serious actions to mitigate global warming effects. As a result, 2019 has been defined the year of the "climate emergency" declaration. In this context, the European Union, which already demonstrated between 1990–2018 that it is possible to decouple gross domestic product (GDP) growth from greenhouse gas emissions<sup>[7]</sup>, set a very ambitious target to achieve carbon neutrality by 2050.

Moreover, the EU admitted that this could not be accomplished with the current commitments under the Paris Agreement that foresee a total greenhouse gas emissions reduction by only 40% in 2030 with respect to 1990 levels. To boost the global warming fighting process, the new European Green Deal<sup>[8]</sup> set a more ambitious target that corresponds to reach a greenhouse gas emissions reduction by at least 50% by 2030 compared with 1990 levels with dedicated strategies for the different sectors. In particular, to decarbonize the heating and cooling sector and to improve the air quality in urban areas, the European Green Deal Investment Plan will support the implementation of district heating and cooling (DHC) networks<sup>[9]</sup>. This technology is the most promising to implement circular economy principles in the heat sector by harvesting and distributing local excess heat that otherwise will be wasted. Moreover, it allows boosting the share of modern renewables to cover the heat demand of buildings that was only equal to about 13.6% in 2017 at a worldwide level<sup>[10]</sup>.

The digital roadmap for district heating and cooling (2019)<sup>[11]</sup>, which has been developed as part of the H2020 project STORM<sup>[12]</sup>, carefully presents how digitalization and the concept of Industry 4.0 can push forward the efficiency and operation of DHC networks, empowering their role in an integrated smart energy system. The barriers identified that could hinder the rollout of digital technologies in DHC are not technical but are mainly related to limitations in acting on the building substation, absence of business models or dynamic tariffs to stimulate the flexibility that can be provided by buildings and regulations on private data protection.

## 2. Overview of Fault Detection and Diagnosis (FDD) in DHC Systems

It is evident that the exploitation of innovative DHC solutions requires the whole system to operate as efficiently as possible<sup>[95]</sup>. However, several authors<sup>[96][97][98][99]</sup> have proved that faults taking place during the operation of energy systems can normally be responsible for up to 40% of their total energy use. Several factors, such as compensation actions triggered by control algorithms or lack of proper maintenance practice, can make these faults remain undetected. Indeed, the manual identification of these faults gets very complicated even if the suboptimal operation of the system is known. This makes the tasks of human maintenance operators really costly, since they only take actions on the system when the indoor environmental thresholds are not met. In this context, automated fault detection and diagnosis (FDD) methods and tools play a key role to assist building and DHC system operators<sup>[100]</sup>.

One typical operating problem in district heating systems indicated by Frederiksen and Werner (2014)<sup>[25]</sup> is the heat carrier loss through water leakage. Water losses occur for several reasons and the corresponding magnitudes of losses also vary. A review of FDD methods to address this problem is presented in [Section 2.1](#). Other operating problems are higher temperature levels due to high return temperatures caused by typical malfunctions such as set-point errors in substations and customer heating systems or short-circuit flows in the thermal grid<sup>[25]</sup>. Since the reduction in the supply temperature is the main objective of 4GDH and 5GDHC in order to exploit renewable and low-grade excess heat sources, assuring a low return temperature is a key aspect in these innovative DHC solutions<sup>[24]</sup>.

In order to avoid malfunctions and faults, maintenance planning becomes crucial to achieve a good service for customers and maintain an economical retrofit for owners. The concept of maintenance includes the administration, control, implementation and quality of those activities, which will ensure that design availability levels and asset performance are achieved in a reasonable way to meet economical and functional objectives. Some definitions of classic maintenance strategies that can be applied are:

- Corrective maintenance is performed to determine, separate and fix a fault so that the failed equipment or facility can be brought back to an operational condition, which lies within in-service operations tolerances.
- Preventive maintenance is performed on a regular basis on a piece of equipment in order to reduce the probability of failure, and it involves a systematic check-up of equipment, thus enabling to detect and correct potential problems.
- Condition-based maintenance consists of a strategy different from preventive maintenance because the maintenance action relies on the actual condition of an asset, rather than average or expected life statistics, to decide what maintenance needs to be done. It imposes that maintenance should only be performed when some indicators show marks of decreasing performance or imminent failure.
- Predictive maintenance is an extension of condition-based maintenance where precise techniques and formulas are used to detect incipient faults and predict their evolution, so the maintenance action can be scheduled before the critical failure in the equipment occurs. Predictive maintenance generally applies non-destructive testing technologies and other specific online methods depending on the type of equipment or process being monitored.
- Proactive maintenance sets corrective actions focused on failure root causes, not on failure symptoms, unlike predictive or preventive maintenance.

There is a huge range of different fault detection (FD) techniques as classified by Granderson et al. (2017)<sup>[101]</sup>. FD methods may be model-based or based purely on process history data, both of them are also called "internally based" methods. The model-based methods depend on knowledge of the basic physical processes and principles governing those system(s) being the target of the analysis. Quantitative model-based approaches are, currently, not frequently used in commercial tool offerings, however qualitative model-based approaches including rule-based fault detection, have been largely applied to industrial environments and provide intuitive representations of engineering principles. The process history-based, also referred as "data-driven FD" is an innovative approach that does not rely upon knowledge of first principles, but on the data from the system in operation from which they may leverage some degree of engineering knowledge. These include statistical regression models, artificial neural networks (ANN), etc. Anyway, a combination of both approaches can be also found in several FDD applications. Moreover, there also exist "externally based" or hardware methods<sup>[102]</sup>, such as visual inspection, infrared image processing or cable methods that usually are not suitable to be included in an automatic fault detection system.

The following sections present a review of the state-of-the-art fault detection approaches and algorithms that are mainly applied in DHC systems, extracted from the review paper *Advanced Control and Fault Detection Strategies for District Heating and Cooling Systems—A Review* <sup>[1]</sup>

## 2.1. Leakage Detection in DHC Networks

Failures on district heating pipes are often caused by water leaks due to corrosion, mechanical impacts and insufficient or deteriorated performance of the thermal insulation solutions, as indicated by Hallberg et al. (2012) <sup>[103]</sup>. However, some degree of leakage is impossible to be avoided during extended operation, since pipeline performance degrades over time. Therefore, an anticipated diagnosis of leakage occurrence is highly necessary to improve efficiency, reduce operating costs and protect the environment. In comparison with DHC networks, both oil/gas and water distribution networks have a longer industrial history. Thus, many established leak detection research results and applications were first applied to such applications. Some representative techniques for pipelines developed for specific fluids (oil, gas or water), different layout patterns, several lengths of pipelines as well as for a certain range of different operating conditions, can be found in <sup>[104]</sup>.

As mentioned above, those methods found in literature are usually divided as “internally-based” (or “software-based”) and “externally-based” (or “hardware-based”), as presented in the review of Zhou et al. (2018) <sup>[105]</sup> for leakage detection in DH networks. Zaman et al. (2020) <sup>[102]</sup> developed and compared “software-based” solutions, both model-based and data-driven, applied through a leakage detection algorithm, whereas a good example of a physical model-based algorithm can be found in Liu et al. (2019) <sup>[106]</sup>. The latter includes a dynamic monitoring module (DMM) and a static testing module (STM): the DMM can detect larger leakages analyzing pressure waves through amplitude propagation and attenuation models; the STM, based on the pressure loss model, can detect micro-leakages, thus being able to act as an effective compensation for the DMM.

As far as data-driven methods are concerned, an application can be found in Xue et al. (2020) <sup>[107]</sup>. It consists of training a decision-tree-based ensemble ML algorithm called XGBoost, using data generated by a simplified physical model and using it to detect leakage in pipes through the collected data from pressure and flow sensors present in the DHC network and substations. A potential obstacle to replicate this approach is the fact that pressure sensors are not always available in the system.

Two interesting proprietary “hardware-based” solutions deserve mentioning. One of them has been developed by the smart meter brand Kamstrup and consists of a leakage detection system based on the analysis of the signal coming from ultrasonic flowmeter installed in substations <sup>[108]</sup>. The other one is based on the well-known impedance method using sensing cables. When a leak takes place, the cable gets saturated with fluid, thus altering its impedance <sup>[109]</sup>. The advantages include high accuracy in determining leak location and easy configuration and maintenance. In contrast, the installation has very high costs and wiring requirements.

In the field of image processing, infrared (IR) sensors are able to capture variations in the heat flow caused by underground fluid leaks, and then show them as hot spots in the DHC system route. This process can be accomplished on the ground, but the availability of high thermal sensitivity and spatial resolution thermal imaging systems mounted on an aerial platform has become the most effective procedure. For instance, data collection can be conducted by an aircraft or drone, which flies over the target area with a camera mounted to the airframe and looking straight down to the ground. This way, thermography reveals sources of heat and the relative differences in temperature from one object to another, as presented in <sup>[110]</sup>. In contrast, postprocessing of IR images may be computationally expensive, and their analysis could lead to false negatives because some color differences caused by a leakage could be almost inappreciable. Some authors such as Zhong et al. (2019) <sup>[111]</sup> and Hossain et al. (2020) <sup>[112]</sup> have developed ML algorithms to improve postprocessing and satisfactorily make the difference between true leakages and other potential causes.

## 2.2. Fault Detection in Substations and Customer Facilities

Nowadays, a current preconceived idea considers that most of the end-use substations in district heating systems work well. This means that it is taken for granted that the facilities deliver or use exactly the right amount of energy to cover customer's needs. Gadd and Werner (2015) <sup>[113]</sup> showed that this is not the case and almost three-quarters of the substations analyzed present faults or symptoms of faults, which could lead to higher return temperatures. This fact is unacceptable especially in 4GDH and 5GDHC, where it is important to achieve a very low return temperature.

In an analysis of the most common faults in DH substations performed as part of the H2020 project TEMPO<sup>[26]</sup>, a survey-based study by Månsson et al. (2019) <sup>[114]</sup> found that the largest fault category was leakages (33%), closely followed by faults in the customers' internal heating systems (31%). This fact reveals that it might be difficult for the energy utilities to get access

to all faults present in the customers' facilities because the DH operators are only usually allowed to access to the substation and not to the internal heating system. Therefore, utilities must make important efforts to establish a good relationship with customers. Common practice to achieve this is to have maintenance contracts with the customers or to include free of charge inspections in the DH agreement. In addition, a proper fault detection system must include customer-sited substations as the main element to inspect. This can be done by analyzing the components of the substation individually, or/and looking at the customer heat load patterns. In the following sections, a literature review of FDD methods for different parts of customer-sited DHC stations is presented.

### 2.2.1. Heat Load Patterns-Based Methods

The heat load in a DH/DC system is the sum of individual heat loads from all customer-sited substations connected to the network and the distribution heat losses. DH/DC heat generation plants might be affected by malfunctions in customer substations and building HVAC systems, which are propagated through the network. The operation of the HVAC system varies depending on the building's end use, so the resulting profile of the heating/cooling load will vary among the different types of buildings. Gadd and Werner<sup>[115]</sup> made a study of 141 different buildings where they first defined two indicators (annual relative daily variation and annual relative seasonal variation) and then used them to detect failures in the DH substations based on high or low variations of these parameters depending on the type of building. Irregularities of the heat load pattern or no correlation between outdoor temperature and heat demand can also be used to detect that the substation is not working properly.

The main challenge related to heat load patterns-based methods is how to deal with such different profiles for various types of buildings or how to create reliable predictions of them. Concerning the first point, a data-driven algorithm enabling large-scale automatic analysis of district heating load patterns was developed by Calikus et al. (2019)<sup>[116]</sup> using an initial dataset of 19.6 million hourly measurements. The algorithm applies clustering techniques to aggregate profiles of customers into different groups and extracts their representative behavioral patterns in terms of heat load. In this way, it is capable of detecting unusual customers whose profiles deviate significantly from the rest of their group. These outliers can be analyzed in depth in order to find problems in the corresponding substations or customer facilities. The application of the algorithm allowed to detect abnormal heat load profiles due to, for instance, a mismatch between the real and designed use of the buildings, problems in the HVAC system that resulted in sharp and irregular afternoon peaks, and summer loads higher than mid-seasons' ones due to substation faults.

In the framework of the H2020 project RELaTED<sup>[49]</sup>, two tools have been developed for automatic fault detection in DH substations based on ML algorithms: DH doctor and DH Autotune<sup>[48]</sup>. The first one exploits clustering, and it is based on daily averaged readings. Anomalies can be detected by measuring the distance among the clusters and following the evolution of the centroids related to a particular variable over time. Moreover, it exploits an ensemble of decision tree (DT) algorithms to make predictions that allow assessing deviations of a monitored variable. The second tool is based on hourly averaged readings and allows the prediction of the load as mentioned in [Section 2.3](#), but also a fast reaction is triggered if abnormal behavior occurs. Alarms are activated if some KPIs, such as MAPE, exceed a threshold. Further applications concerning the prediction of substation heat demand patterns through ML algorithms using the usual metering variables such as flows and temperatures can be found in<sup>[117][118][119]</sup>.

### 2.2.2. Fouling Detection in Heat Exchangers

When focusing on operational faults specifically related to heat exchangers, the literature shows that most of them commonly involve fouling formation<sup>[118]</sup>. This can be described as the accumulation of deposits on heat transferring surfaces, which cause a higher thermal and hydraulic resistance in the heat exchanger. An automatic method using the usual metering variables such as volumetric flow and temperatures in the substation primary and secondary circuits has been developed by Guelpa and Verda (2020)<sup>[120]</sup>. It consists of the indirect calculation of the global heat transfer coefficient and monitoring its change during the fouling process. This method is easy to implement but involves important calibration challenges when it comes to different kinds of heat exchangers.

### 2.2.3. Detection of Regulation Valves Malfunctioning

The actuator of the control valves or the valves themselves may wear and tear during operation or after large periods without use. This causes uncontrolled flows in the installation and instability of the flow rate. An analysis of frequency variation and stability of the flow in the primary circuit of the substation was performed by Fabre et al. (2020)<sup>[121]</sup> leading to a simple and easy method to detect this kind of fault.

#### 2.2.4. Malfunction in Heat Pump Components

Heat pumps (HPs) at the customer-sited substations are used in 4GDH systems as booster stations for DHW production, whereas in 5GDHC systems, they are needed to supply both space heating/cooling and DHW loads at the right temperature for the distribution and emission system. Due to that, it is really important to assure an efficient operation detecting possible faults and to prevent them. A comprehensive study that analyzes the most important faults reported by both original equipment manufacturers (OEMs) and insurance companies in Sweden is presented in<sup>[122]</sup>. The results state that the issues in control and electronics are one of the most common and costliest faults in all types of HPs. According to OEMs, the shuttle and shunt valves are the second most common faults that occurred in ground source and exhaust air HP systems, respectively. Unfortunately, there are not any investigations in the current literature about fault detection applied to these specific parts. Moreover, an additional impediment for the development and implementation of the HPs fault detection algorithm is the fact that the equipped software is often a closed system that can only be accessed by the manufacturer. However, there exist some studies leading to detect leaky check and reversing valves using their own test benches or modified commercial heating pumps to be able to measure internal temperatures and mass flow of the refrigerant<sup>[123]</sup>.

It is proved that for HP systems, there is a maximum coefficient of performance (COP) at the optimal charge amount and refrigerant leakages cause performance degradation and a decrease in thermal comfort<sup>[124]</sup>. However, several heat-pump-based units usually do not have an optimal amount of refrigerant. For this reason, it is important to detect these leakages in an early phase to be able to fix them without energy losses and to limit their contribution to global warming. Several studies have been developed in this direction. For instance, Eom et al. (2019)<sup>[125]</sup> proposed a novel refrigerant charge fault detection strategy for HPs using convolutional neural networks trained using a real commercial HP system and the variables used for internal control provided by the manufacturer. Sun et al. (2020)<sup>[126]</sup> defined the sub-health operation concept of HP systems, which is used to define the intermediate state between normal and fault. Moreover, an online undercharge sub-health diagnosis method was proposed that analyses the theoretical behavior of the system facing a refrigerant leakage.

Even though it seems that every time more algorithms used for fault detection are based on neural networks and machine learning techniques, a recent study concludes that some of these approaches are not useful when working with real data series from heat pumps<sup>[95]</sup>.

#### 2.3. Diagnostics of Sensors and Actuators

The digitalization of the DHC sector is becoming crucial. Moreover, in order to control efficiently the systems and to be able to detect malfunctions, the introduction of more and new sensors and actuators is necessary. However, these components may also fail, and it is important to be able to detect it. There are several simple complementary methods, which should be implemented in all sensors and actuators of the whole facility:

- Monitoring of raw voltage/current sensor signals to detect short circuits to detect out-of-range values.
- Monitoring of incoherent values of the measures such as instabilities or impossible values to reach (e.g., ambient temperature above 70 °C).
- Considering the size of deviation, duration of the fault and average frequency of appearance.
- Creation of strategies identifying when the actuators and sensor will be tested, taking advantage of specific operation points such as stationary behavior, opening/closing of valves, etc. The continuous diagnosis of some variables may lead to false fault detection, which may suppose an extra cost for maintenance companies.

In the literature, some specific methods applied to heat pump (HP) sensors are investigated. Zhang et al. (2019)<sup>[127]</sup> propose a data-driven statistical model optimized and applied for sensor fault detection and diagnosis (FDD) using subtraction clustering and k-means clustering combined to identify and classify modelling measurements of unsteady operating conditions. Moreover, in order to calibrate the HP sensors, a method called virtual in situ calibration (VIC), based on the Bayesian inference and Markov Chain Monte Carlo (MCMC), was very effective in detecting and correcting the systematic and random errors of various sensors installed in a PVT/heat pump system<sup>[119]</sup>. As the VIC method can effectively improve the measurement certainty, the sensors with relatively low accuracy can be used to achieve a higher precision, which is able to significantly reduce the cost of equipment. VIC uses a certain grade of modelling, and it seems not so hard to implement.

### 3. Conclusions

With the growth of the world's population and an increase in urbanization, district heating and cooling (DHC) has been identified as a promising technology to cover the thermal energy demands in urban areas. Notwithstanding, DHC is evolving towards lower distribution temperatures, the exploitation of decentralized and non-programmable renewable sources and sector-coupling with other energy carriers. However, the lack of optimal control strategies and fault detection tools leads DHC systems to waste energy and resources. Moreover, new challenges such as demand-side management, weather uncertainty and environmental efficiency have emerged. Those have attracted more and more attention to the design of intelligent, robust control platforms as well as diagnostic methods. These advanced solutions, reviewed in this paper <sup>[1]</sup> with a focus on low-temperature DH studies and EU research projects, must be able to predict events, make real-time decisions and be integrated with SCADA systems in order to push the DHC sector forward in the digital transition.

In fault detection and diagnosis (FDD), two main approaches emerged: physical-based versus data-driven modelling. Models here are useful in software-based solutions to detect malfunctions from the deviation of the system from standard operation. Alarms can be activated when some calibrated thresholds are exceeded. The use of machine-learning-based FDD tools is growing in DHC, since they can handle complex systems with a large number of variables and have excellent performance in the behavior prediction of non-linear systems and in pattern recognition. However, these solutions have some drawbacks, since large datasets are needed for training over different operating conditions to avoid low performance in the extrapolation in real-time operation. Among hardware-based FDD approaches, infrared thermography found applications for leak detections in DHC pipeline and can be further boosted by means of automatic image recognition algorithms. Predictive control and fault detection sometimes share similar approaches and from the survey performed emerges that some companies developed innovative platforms based on artificial intelligence for both applications. <sup>[1]</sup>

## **Nomenclature and Abbreviations**

5GDHC Fifth-generation district heating and cooling

4GDH Fourth-generation district heating

AI Artificial intelligence

ANN Artificial neural network

CHP Combined heat and power

COP Coefficient of performance

DC District cooling

DH District heating

DHC District heating and cooling

DHW Domestic hot water

DP Dynamic programming

DR Demand response

DSM Demand-side management

DT Decision treesERT Extremely randomized trees

ETS Energy transfer station

FDD Fault detection and diagnosis

GA Genetic algorithm

HP Heat pump

HVAC Heating ventilation and air conditioning

LP Linear programming

LR Linear regression

MAPE Mean absolute percentage error

MAS Multi-agent system

MILP Mixed-integer linear programming

ML Machine learning

MLR Multiple linear regression

MPC Model predictive control

PLS Partial least square

PSO Particle swarm optimization

PV Photovoltaic

RBC Rule-based controller

RF Random forest

RNN recurrent neural network

SARIMA Seasonal autoregressive integrated moving average  
 SCADA Supervisory control and data acquisition  
 SH Space heating  
 SVM Support vector machine  
 TES Thermal energy storage  
 ULTDH Ultra-low temperature district heating

## References

1. Simone Buffa; Mohammad Hossein Fouladfar; Giuseppe Franchini; Ismael Lozano Gabarre; Manuel Andrés Chicote; Advanced Control and Fault Detection Strategies for District Heating and Cooling Systems—A Review. *Applied Sciences* **2021**, *11*, 455, 10.3390/app11010455.
2. United Nations, Department of Economic and Social Affairs/Population Division. World Urbanization Prospects: The 2018 Revision; United Nations: New York, NY, USA, 2019; ISBN 978-92-1-148319-2.
3. Revesz, A.; Jones, P.; Dunham, C.; Davies, G.; Marques, C.; Matabuena, R.; Scott, J.; Maidment, G. Developing novel 5th generation district energy networks. *Energy* **2020**, *201*, 117389.
4. Russo, S.; Sillmann, J.; Fischer, E.M. Top ten European heatwaves since 1950 and their occurrence in the coming decades. *Environ. Res. Lett.* **2015**, *10*, 124003.
5. Masson-Delmotte, V.; Zhai, P.; Pörtner, H.-O.; Roberts, D.; Skea, J.; Shukla, P.R.; Pirani, A.; Moufouma-Okia, W.; Péan, C.; Pidcock, R.; et al. Global Warming of 1.5 °C. An IPCC Special Report on the Impacts of Global Warming of 1.5 °C above Pre-Industrial Levels and Related Global Greenhouse Gas. Emission Pathways, in the Context of Strengthening the Global Response to the Threat of Climate Change, Sustainable Development, and Efforts to Eradicate Poverty; IPCC: Hong Kong, China, 2018.
6. Zebisch, M. The Climate Crisis is COVID-19 in Slow Motion. So What Can We Learn? Presented Online at the Beyond Crisis Conference, Free University of Bozen–Bolzano, 17–18 April 2020; 2020. Available online: <https://designdisaster.unibz.it/beyond-crisis-outcomes-next-steps/> (accessed on 2 October 2020).
7. Kliewer, A. Climate Change is Coronavirus in Slow Motion. Available online: <https://medium.com/age-of-awareness/climate-change-is-coronavirus-in-slow-motion-b8932f8e2905> (accessed on 5 October 2020).
8. European Commission. The EU's Track Record on Climate Action, The European Green Deal; European Commission: Brussels, Belgium, 2019; Available online: [https://ec.europa.eu/commission/presscorner/detail/en/fs\\_19\\_6720](https://ec.europa.eu/commission/presscorner/detail/en/fs_19_6720) (accessed on 1 October 2020).
9. European Commission. The European Green Deal; European Commission: Brussels, Belgium, 2019; Available online: <https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=CELEX%3A52019DC0640> (accessed on 1 October 2020).
10. European Commission. The European Green Deal Investment Plan and Just Transition Mechanism explained. Available online: [https://ec.europa.eu/commission/presscorner/detail/en/qanda\\_20\\_24](https://ec.europa.eu/commission/presscorner/detail/en/qanda_20_24) (accessed on 5 October 2020).
11. REN21. Renewables 2020 Global Status Report; REN21: Paris, France, 2020.
12. DHC+ Technology Platform; Euroheat and Power. Digital Roadmap for District Heating & Cooling. 2019. Available online: [https://www.euroheat.org/wp-content/uploads/2018/05/Digital-Roadmap\\_final.pdf](https://www.euroheat.org/wp-content/uploads/2018/05/Digital-Roadmap_final.pdf) (accessed on 11 October 2020).
13. EU H2020 STORM Project. Available online: <https://storm-dhc.eu> (accessed on 7 October 2020).
14. EU H2020 REWARDHeat Project. Available online: <https://www.rewardheat.eu> (accessed on 7 October 2020).
15. Vandermeulen, A.; van der Heijde, B.; Helsen, L. Controlling district heating and cooling networks to unlock flexibility: A review. *Energy* **2018**, *151*, 103–115.
16. Talebi, B.; Mirzaei, P.A.; Bastani, A.; Haghighat, F. A Review of District Heating Systems: Modeling and Optimization. *Front. Built Environ.* **2016**, *2*, 22.

17. IRENA; OECD/IEA; REN21. Renewable Energy Policies in a Time of Transition: Heating and Cooling; IRENA: Abu Dhabi, UAE, 2020; p. 150. Available online: <https://www.iea.org/reports/renewable-energy-policies-in-a-time-of-transition-heating-and-cooling> (accessed on 15 December 2020).
18. Persson, U.; Werner, S. Stratego EU Project: Quantifying the Heating and Cooling Demand in Europe. 2015. Available online: <https://heatroadmap.eu/wp-content/uploads/2018/09/STRATEGO-WP2-Background-Report-4-Heat-Cold-Demands.pdf> (accessed on 4 November 2020).
19. DHC+ Technology Platform Steering Committee. District heating & cooling: A vision towards 2020-2030-2050. In Proceedings of the 34th Euroheat & Power Congress, Venice, Italy, 25–26 May 2009.
20. European Geothermal Energy Council (EGEC). EGEC Geothermal Market Report 2019; EGEC: Brussels, Belgium, 2020.
21. GeoDH Project. Developing Geothermal District Heating in Europe. 2014. Available online: [http://geodh.eu/wp-content/uploads/2012/07/GeoDH-Report-2014\\_web.pdf](http://geodh.eu/wp-content/uploads/2012/07/GeoDH-Report-2014_web.pdf) (accessed on 3 December 2020).
22. PlanEnergi. 1 GW Solar District Heating in Denmark. Available online: <https://planenergi.eu/activities/district-heating/solar-district-heating/1-gw-sdh-in-dk/> (accessed on 1 December 2020).
23. Tian, Z.; Zhang, S.; Deng, J.; Fan, J.; Huang, J.; Kong, W.; Perers, B.; Furbo, S. Large-scale solar district heating plants in Danish smart thermal grid: Developments and recent trends. *Energy Convers. Manag.* 2019, 189, 67–80.
24. Marx, R.; Bauer, D.; Drucek, H. Energy Efficient Integration of Heat Pumps into Solar District Heating Systems with Seasonal Thermal Energy Storage. *Energy Procedia* 2014, 57, 2706–2715.
25. Buffa, S.; Cozzini, M.; D'Antoni, M.; Baratieri, M.; Fedrizzi, R. 5th generation district heating and cooling systems: A review of existing cases in Europe. *Renew. Sustain. Energy Rev.* 2019, 104, 504–522.
26. Frederiksen, S.; Werner, S. District Heating and Cooling; Studentlitteratur: Lund, Sweden, 2014.
27. Leoni, P.; Bres, A.; Marini, I.; Capretti, A. Lowering the operating temperatures in old-generation district heating systems: First results from the TEMPO demonstration project in Brescia (Italy). Presented Online at the 6th International Conference on Smart Energy Systems, 6–7 October 2020; Available online: <https://smartenergysystems.eu/> (accessed on 1 December 2020).
28. EU H2020 REWARDHeat Project: Albertslund Shunt. Available online: <https://www.rewardheat.eu/en/News-%26-Events/Albertslund-shunt> (accessed on 20 October 2020).
29. Svendsen, S.; Østergaard, D.S.; Yang, X. Solutions for low temperature heating of rooms and domestic hot water in existing buildings. In Proceedings of the 3rd International Conference on Smart Energy Systems and 4th Generation District Heating, Copenhagen, Denmark, 12–13 September 2017.
30. Marella, T.; Zarotti, G.; Bosco, D. Riqualificare un immobile storico con pompa di calore VRV. *AICARR J.* 2014, 24, 48–56.
31. Stene, J.; Eggen, G. Heat pump system with distribution at intermediate temperature at the University of Bergen. In Proceedings of the 19th International Congress of Refrigeration, The Hague, The Netherlands, 20–25 August 1995.
32. Vetterli, N.; Sulzer, M. Dynamic analysis of the low-temperature district network “Suurstoffi” through monitoring. In Proceedings of the International Conference CISBAT 2015 Future Buildings and Districts Sustainability from Nano to Urban Scale, Lausanne, Switzerland, 9–11 September 2015.
33. Volkova, A.; Mašatin, V.; Siirde, A. Methodology for evaluating the transition process dynamics towards 4th generation district heating networks. *Energy* 2018, 150, 253–261.
34. EU H2020 OPTi Project. Available online: <http://www.opti2020.eu/> (accessed on 7 October 2020).
35. Johansson, C.; Bergkvist, M.; Geysen, D.; Somer, O.D.; Lavesson, N.; Vanhoudt, D. Operational Demand Forecasting in District Heating Systems Using Ensembles of Online Machine Learning Algorithms. *Energy Procedia* 2017, 116, 208–216.



36. Geysen, D.; De Somer, O.; Johansson, C.; Brage, J.; Vanhoudt, D. Operational thermal load forecasting in district heating networks using machine learning and expert advice. *Energy Build.* 2018, 162, 144–153.
37. Suryanarayana, G.; Lago, J.; Geysen, D.; Aleksiejuk, P.; Johansson, C. Thermal load forecasting in district heating networks using deep learning and advanced feature selection methods. *Energy* 2018, 157, 141–149.
38. Choudhury, A.R. Demand Forecasting in DHC-network using machine learning models. In *Proceedings of the Eighth International Conference on Future Energy Systems*, Shatin, Hong Kong, China, 16–19 May 2017; pp. 367–372.
39. Saurav, K.; Chandan, V. Gray-Box Approach for Thermal Modelling of Buildings for Applications in District Heating and Cooling Networks. In *Proceedings of the Eighth International Conference on Future Energy Systems*, Shatin, Hong Kong, China, 16–19 May 2017; pp. 347–352.
40. Idowu, S.; Saguna, S.; Åhlund, C.; Schelén, O. Applied machine learning: Forecasting heat load in district heating system. *Energy Build.* 2016, 133, 478–488.
41. Dalipi, F.; Yildirim Yayilgan, S.; Gebremedhin, A. Data-Driven Machine-Learning Model in District Heating System for Heat Load Prediction: A Comparison Study. *Appl. Comput. Intell. Soft Comput.* 2016, 2016, 3403150.
42. Shamshirband, S.; Petković, D.; Enayatifar, R.; Hanan Abdullah, A.; Marković, D.; Lee, M.; Ahmad, R. Heat load prediction in district heating systems with adaptive neuro-fuzzy method. *Renew. Sustain. Energy Rev.* 2015, 48, 760–767.
43. Xue, G.; Pan, Y.; Lin, T.; Song, J.; Qi, C.; Wang, Z. District Heating Load Prediction Algorithm Based on Feature Fusion LSTM Model. *Energies* 2019, 12, 2122.
44. Kato, K.; Sakawa, M.; Ishimaru, K.; Ushiro, S.; Shibano, T. Heat load prediction through recurrent neural network in district heating and cooling systems. In *Proceedings of the 2008 IEEE International Conference on Systems, Man and Cybernetics*, Singapore, 12–15 October 2008.
45. Nielsen, H.A.; Madsen, H. Modelling the heat consumption in district heating systems using a grey-box approach. *Energy Build.* 2006, 38, 63–71.
46. Saarinen, L. *Modelling and Control of a District Heating System*; Uppsala University: Uppsala, Sweden, 2008.
47. Grosswindhager, S.; Voigt, A.; Kozek, M. Online Short-Term Forecast of System Heat Load in District Heating Networks. *TSP* 2011, 1, 8.
48. Chramcov, B. Heat demand forecasting for concrete district heating system. *Math. Models Methods Appl. Sci.* 2010, 4, 231–239.
49. Fester, J.; Østergaard, P.F.; Lumberras Mugaguren, M.; Garay Martinez, R. H2020 RELaTED Project-D2.4: Energy Flexibility and DH Control. 2019. Available online: [http://www.relatedproject.eu/wp-content/uploads/2019/10/RELaTED\\_D2\\_4\\_Energy\\_Flexibility\\_and\\_DH\\_Control\\_V4.0.pdf](http://www.relatedproject.eu/wp-content/uploads/2019/10/RELaTED_D2_4_Energy_Flexibility_and_DH_Control_V4.0.pdf) (accessed on 17 October 2020).
50. EU H2020 RELaTED Project. Available online: <http://www.relatedproject.eu> (accessed on 7 October 2020).
51. Guelpa, E.; Marincioni, L.; Capone, M.; Deputato, S.; Verda, V. Thermal load prediction in district heating systems. *Energy* 2019, 176, 693–703.
52. Ma, W.; Fang, S.; Liu, G.; Zhou, R. Modeling of district load forecasting for distributed energy system. *Appl. Energy* 2017, 204, 181–205.
53. Borrelli, F.; Bemporad, A.; Morari, M. *Predictive Control for Linear and Hybrid Systems*; Cambridge University Press: Cambridge, UK, 2017.
54. Saletti, C.; Gambarotta, A.; Morini, M. Development, analysis and application of a predictive controller to a small-scale district heating system. *Appl. Therm. Eng.* 2020, 165, 114558.
55. De Lorenzi, A.; Gambarotta, A.; Morini, M.; Rossi, M.; Saletti, C. Setup and testing of smart controllers for small-scale district heating networks: An integrated framework. *Energy* 2020, 205, 118054.

56. Verrilli, F.; Srinivasan, S.; Gambino, G.; Canelli, M.; Himanka, M.; Del Vecchio, C.; Sasso, M.; Glielmo, L. Model Predictive Control-Based Optimal Operations of District Heating System with Thermal Energy Storage and Flexible Loads. *IEEE Trans. Automat. Sci. Eng.* 2017, 14, 547–557.
57. Labidi, M.; Eynard, J.; Faugeron, O.; Grieu, S. Predictive Control and Optimal Design of Thermal Storage Systems for Multi-energy District Boilers. *IFAC Proc. Vol.* 2014, 47, 10305–10310.
58. Lennermo, G.; Lauenburg, P.; Werner, S. Control of decentralised solar district heating. *Sol. Energy* 2019, 179, 307–315.
59. Grosswindhager, S.; Voigt, A.; Kozek, M. Predictive Control of District Heating Network using Fuzzy DMC. In *Proceedings of the 2012 International Conference on Modelling, Identification and Control, Hong Kong, China, 19–20 December 2012*.
60. Lazzeroni, P. Design of a polygeneration system with optimal management for a dhc network. *Int. J. Sustain. Energy Plan. Manag.* 2019, 22.
61. Wirtz, M.; Kivilip, L.; Remmen, P.; Müller, D. 5th Generation District Heating: A novel design approach based on mathematical optimization. *Appl. Energy* 2020, 260, 114158.
62. Samsatli, S.; Samsatli, N.J. A general mixed integer linear programming model for the design and operation of integrated urban energy systems. *J. Clean. Prod.* 2018, 191, 458–479.
63. Buoro, D.; Pinamonti, P.; Reini, M. Optimization of a Distributed Cogeneration System with solar district heating. *Appl. Energy* 2014, 124, 298–308.
64. EU H2020 FLEXYNETS Project. Available online: [www.flexynets.eu](http://www.flexynets.eu) (accessed on 7 October 2020).
65. Vivian, J.; Jobard, X.; Hassine, I.B.; Pietrushka, D.; Hurink, J.L. Smart Control of a District Heating Network with High Share of Low Temperature Waste Heat. In *Proceedings of the 12th Conference on Sustainable Development of Energy, Water and Environmental Systems-SDEWES, Dubrovnik, Croatia, 4–8 October 2017*.
66. Schütz, T.; Streblow, R.; Müller, D. A comparison of thermal energy storage models for building energy system optimization. *Energy Build.* 2015, 93, 23–31.
67. Giraud, L.; Merabet, M.; Baviere, R.; Vallée, M. Optimal Control of District Heating Systems using Dynamic Simulation and Mixed Integer Linear Programming. In *Proceedings of the 12th International Modelica Conference, Prague, Czech Republic, 15–17 May 2017*.
68. Giraud, L. A control method of DH systems based on production and distribution optimization. Presented at the En+Eff-22nd International TradeFair and Congress, Frankfurt, Germany, 20 April 2016; Available online: [https://www.lsta.lt/files/events/2016-04-18\\_EHPkonfer/Pranesimai/Sesija%20I/L.GIRAUD.pdf](https://www.lsta.lt/files/events/2016-04-18_EHPkonfer/Pranesimai/Sesija%20I/L.GIRAUD.pdf) (accessed on 20 October 2020).
69. Urbanucci, L.; D'Ettorre, F.; Testi, D. A Comprehensive Methodology for the Integrated Optimal Sizing and Operation of Cogeneration Systems with Thermal Energy Storage. *Energies* 2019, 12, 875.
70. Casisi, M.; Costanzo, S.; Pinamonti, P.; Reini, M. Two-Level Evolutionary Multi-objective Optimization of a District Heating System with Distributed Cogeneration. *Energies* 2018, 12, 114.
71. Logenthiran, T.; Srinivasan, D. Multi-agent system for managing a power distribution system with Plug-in Hybrid Electrical vehicles in smart grid. In *Proceedings of the ISGT2011-India, Kerala, India, 1–3 December 2011*.
72. Wemstedt, F.; Davidsson, P. An Agent-Based Approach to Monitoring and Control of District Heating Systems. In *Proceedings of the 15th International Conference on Industrial and Engineering, Cairns, Australia, 22–27 September 2002*.
73. Johansson, C.; Wernstedt, F.; Davidsson, P. Deployment of Agent Based Load Control in District Heating Systems. In *Proceedings of the First International Workshop on AgentTechnologies for Energy Systems, Canada, Toronto, ON, Canada, 10–11 May 2010*.
74. Lacroix, B.; Paulus, C.; Mercier, D. Multi-Agent Control of Thermal Systems in Buildings. In *Proceedings of the Agent Technologies in Energy Systems, Valencia, Spain, 5 June 2012*.

75. Wang, Z.; Wang, L.; Dounis, A.I.; Yang, R. Multi-agent control system with information fusion based comfort model for smart buildings. *Appl. Energy* 2012, 99, 247–254.
76. Bünning, F.; Wetter, M.; Fuchs, M.; Müller, D. Bidirectional low temperature district energy systems with agent-based control: Performance comparison and operation optimization. *Appl. Energy* 2018, 209, 502–515.
77. Faugeras, A. Interreg D2Grids Project-D4.1: Blockchain & Smartcontract, State of the Art of the Energy Market. 2019. Available online: [https://www.nweurope.eu/media/9871/191004\\_d2grids\\_blockchain\\_and\\_smart\\_contract\\_state\\_of\\_the\\_art\\_on\\_the\\_energy\\_market](https://www.nweurope.eu/media/9871/191004_d2grids_blockchain_and_smart_contract_state_of_the_art_on_the_energy_market) (accessed on 4 October 2020).
78. Construction21. A Demonstrator Project to Use of the Blockchain on a 5th Generation Heating Network. Available online: <https://www.construction21.org/articles/h/A-demonstrator-project-to-use-of-the-Blockchain-on-a-5th-generation-heating-network.html> (accessed on 4 October 2020).
79. Demand Response Application in Smart Grids: Concepts and Planning Issues-Volume 1; Nojavan, S.; Zare, K. (Eds.) Springer International Publishing: Cham, Switzerland, 2020; ISBN 978-3-030-31398-2.
80. Corbin, C.D.; Henze, G.P. Predictive control of residential HVAC and its impact on the grid. Part I: Simulation framework and models. *J. Build. Perform. Simul.* 2017, 10, 294–312.
81. Fischer, D.; Wolf, T.; Wapler, J.; Hollinger, R.; Madani, H. Model-based flexibility assessment of a residential heat pump pool. *Energy* 2017, 118, 853–864.
82. Vivian, J.; Prataviera, E.; Cunsolo, F.; Pau, M. Demand Side Management of a pool of air source heat pumps for space heating and domestic hot water production in a residential district. *Energy Convers. Manag.* 2020, 225, 113457.
83. EU H2020 Project Sim4Blocks. Available online: <http://www.sim4blocks.eu> (accessed on 8 October 2020).
84. Brennenstuhl, M.; Zeh, R.; Otto, R.; Pesch, R.; Stockinger, V.; Pietruschka, D. Report on a Plus-Energy District with Low-Temperature DHC Network, Novel Agrothermal Heat Source, and Applied Demand Response. *Appl. Sci.* 2019, 9, 5059.
85. Romero Rodríguez, L.; Brennenstuhl, M.; Yadack, M.; Boch, P.; Eicker, U. Heuristic optimization of clusters of heat pumps: A simulation and case study of residential frequency reserve. *Appl. Energy* 2019, 233–234, 943–958.
86. Guelpa, E.; Marincioni, L.; Deputato, S.; Capone, M.; Amelio, S.; Pochettino, E.; Verda, V. Demand side management in district heating networks: A real application. *Energy* 2019, 182, 433–442.
87. Capone, M.; Guelpa, E.; Verda, V. Optimal operation of district heating networks through demand response. *Int. J. Thermodyn.* 2019, 22, 35–43.
88. Guelpa, E.; Marincioni, L. Demand side management in district heating systems by innovative control. *Energy* 2019, 188, 116037.
89. Romanchenko, D.; Nyholm, E.; Odenberger, M.; Johnsson, F. Flexibility Potential of Space Heating Demand Response in Buildings for District Heating Systems. *Energies* 2019, 12, 2874.
90. Kota, R. H2020 Project OPTi-D5.3: Automated DR Algorithms Specification. Available online: <http://www.opti2020.eu/wp-content/uploads/2019/07/D5.3-Automated-DR-algorithms-specification.pdf> (accessed on 1 December 2020).
91. EU H2020 E2District Project. Available online: <https://cordis.europa.eu/project/id/696009/results> (accessed on 8 October 2020).
92. Beder, C.; Blanke, J.; Klepal, M. Behaviour Demand Response in District Heating—A Simulation-Based Assessment of Potential Energy Savings. *Proceedings* 2019, 20, 2.
93. Wu, Y.; Mäki, A.; Jokisalo, J.; Kosonen, R.; Kilpeläinen, S.; Salo, S.; Liu, H.; Li, B. Demand response of district heating using model predictive control to prevent the draught risk of cold window in an office building. *J. Build. Eng.* 2021, 33, 101855.
94. Knudsen, M.D.; Petersen, S. Model predictive control for demand response of domestic hot water preparation in ultra-low temperature district heating systems. *Energy Build.* 2017, 146, 55–64.

95. Buffa, S.; Soppelsa, A.; Pipiciello, M.; Henze, G.; Fedrizzi, R. Fifth-Generation District Heating and Cooling Substations: Demand Response with Artificial Neural Network-Based Model Predictive Control. *Energies* 2020, 13, 4339.
96. Bode, G.; Thul, S.; Baranski, M.; Müller, D. Real-world application of machine-learning-based fault detection trained with experimental data. *Energy* 2020, 198, 117323.
97. Piette, M.A.; Kinney, S.K.; Haves, P. Analysis of an information monitoring and diagnostic system to improve building operations. *Energy Build.* 2001, 33, 783–791.
98. Katipamula, S.; Brambley, M. Review Article: Methods for Fault Detection, Diagnostics, and Prognostics for Building Systems—A Review, Part I. *HVAC R Res.* 2005, 11, 3–25.
99. Katipamula, S.; Brambley, M. Review Article: Methods for Fault Detection, Diagnostics, and Prognostics for Building Systems—A Review, Part II. *HVAC R Res.* 2005, 11, 169–187.
100. Yu, Y.; Woradechjumroen, D.; Yu, D. A review of fault detection and diagnosis methodologies on air-handling units. *Energy Build.* 2014, 82, 550–562.
101. Sterling, R.; Struß, P.; Febres, J.; Sabir, U.; Keane, M. From Modelica Models to Fault Diagnosis in Air Handling Units. In *Proceedings of the 10 th International Modelica Conference*, Lund, Sweden, 10–12 March 2014.
102. Granderson, J.; Singla, R.; Mayhorn, E.; Ehrlich, P.; Vrabie, D.; Frank, S. Characterization and Survey of Automated Fault Detection and Diagnostic Tools; Lawrence Berkeley National Laboratory: Berkeley, CA, USA, 2017.
103. Zaman, D.; Tiwari, M.K.; Gupta, A.K.; Sen, D. A review of leakage detection strategies for pressurised pipeline in steady-state. *Eng. Fail. Anal.* 2020, 109, 104264.
104. Hallberg, D.; Stojanović, B.; Akander, J. Status, needs and possibilities for service life prediction and estimation of district heating distribution networks. *Struct. Infrastruct. Eng.* 2012, 8, 41–54.
105. Datta, S.; Sarkar, S. A review on different pipeline fault detection methods. *J. Loss Prev. Process. Ind.* 2016, 41, 97–106.
106. Zhou, S.; O'Neill, Z.; O'Neill, C. A review of leakage detection methods for district heating networks. *Appl. Therm. Eng.* 2018, 137, 567–574.
107. Liu, C.; Li, Y.; Xu, M. An integrated detection and location model for leakages in liquid pipelines. *J. Pet. Sci. Eng.* 2019, 175, 852–867.
108. Xue, P.; Jiang, Y.; Zhou, Z.; Chen, X.; Fang, X.; Liu, J. Machine learning-based leakage fault detection for district heating networks. *Energy Build.* 2020, 223, 110161.
109. Kamstrup. Real-Life Innovation, Skanderborg Utility, Denmark. Available online: <https://www.kamstrup.com/en-en/customer-references/water/case-skanderborg-real-life-innovation> (accessed on 20 October 2020).
110. Alaska Department of Environmental Conservation. Technical Review of Leak Detection Technologies. 1999. Available online: <https://dec.alaska.gov/media/8147/vol1-crude-oil-transmission-pipeline.pdf> (accessed on 20 October 2020).
111. Stockton, G.R. Aerial Infrared—An Asset Management Tool for District Heating System Operators. Available online: [https://reliabilityweb.com/articles/entry/aerial\\_infrared\\_an\\_asset\\_management\\_tool\\_for\\_district\\_heating\\_system\\_operat/](https://reliabilityweb.com/articles/entry/aerial_infrared_an_asset_management_tool_for_district_heating_system_operat/) (accessed on 20 October 2020).
112. Zhong, Y.; Xu, Y.; Wang, X.; Jia, T.; Xia, G.; Ma, A.; Zhang, L. Pipeline leakage detection for district heating systems using multisource data in mid- and high-latitude regions. *ISPRS J. Photogramm. Remote Sens.* 2019, 151, 207–222.
113. Hossain, K.; Villebro, F.; Forchhammer, S. UAV image analysis for leakage detection in district heating systems using machine learning. *Pattern Recognit. Lett.* 2020, 140, 158–164.
114. Gadd, H.; Werner, S. Fault detection in district heating substations. *Appl. Energy* 2015, 157, 51–59.

115. Månsson, S.; Johansson Kallioniemi, P.-O.; Thern, M.; Van Oevelen, T.; Sernhed, K. Faults in district heating customer installations and ways to approach them: Experiences from Swedish utilities. *Energy* 2019, 180, 163–174.
116. Gadd, H.; Werner, S. Heat load patterns in district heating substations. *Appl. Energy* 2013, 108, 176–183.
117. Calikus, E.; Nowaczyk, S.; Sant'Anna, A.; Gadd, H.; Werner, S. A data-driven approach for discovering heat load patterns in district heating. *Appl. Energy* 2019, 252, 113409.
118. Sakawa, M. Prediction and operational planning in district heating and cooling systems. In *Advance District Heating and Cooling (DHC) Systems*; Elsevier: Amsterdam, The Netherlands, 2016; pp. 259–289.
119. Månsson, S.; Kallioniemi, P.-O.J.; Sernhed, K.; Thern, M. A machine learning approach to fault detection in district heating substations. *Energy Procedia* 2018, 149, 226–235.
120. Wang, P.; Li, J.; Yoon, S.; Zhao, T.; Yu, Y. The detection and correction of various faulty sensors in a photovoltaic thermal heat pump system. *Appl. Therm. Eng.* 2020, 175, 115347.
121. Guelpa, E.; Verda, V. Automatic fouling detection in district heating substations: Methodology and tests. *Appl. Energy* 2020, 258, 114059.
122. Fabre, A.; Tran, C.-T.; Duplessis, B.; Stabat, P. Substation Malfunction Detection Indicators to Improve the Operation of District Heating Networks. 8th International DHC+ Student Awards. 2020. Available online: <https://www.euroheat.org/dhc-student-awards/8th-international-dhc-student-awards/> (accessed on 26 December 2020).
123. Madani, H. The Common and Costly Faults in Heat Pump Systems. *Energy Procedia* 2014, 61, 1803–1806.
124. Li, H.; Braun, J.E. Decoupling features for diagnosis of reversing and check valve faults in heat pumps. *Int. J. Refrig.* 2009, 32, 316–326.
125. Kim, D.H.; Park, H.S.; Kim, M.S. The effect of the refrigerant charge amount on single and cascade cycle heat pump systems. *Int. J. Refrig.* 2014, 40, 254–268.
126. Eom, Y.H.; Yoo, J.W.; Hong, S.B.; Kim, M.S. Refrigerant charge fault detection method of air source heat pump system using convolutional neural network for energy saving. *Energy* 2019, 187, 115877.
127. Sun, Z.; Jin, H.; Gu, J.; Huang, Y.; Wang, X.; Yang, H.; Shen, X. Studies on the online intelligent diagnosis method of undercharging sub-health air source heat pump water heater. *Appl. Therm. Eng.* 2020, 169, 114957.
128. Zhang, H.; Chen, H.; Guo, Y.; Wang, J.; Li, G.; Shen, L. Sensor fault detection and diagnosis for a water source heat pump air-conditioning system based on PCA and preprocessed by combined clustering. *Appl. Therm. Eng.* 2019, 160, 114098.

---

Retrieved from <https://encyclopedia.pub/entry/history/show/16818>